

Wymagane minimalne usuwanie substancji organicznych w procesie koagulacji, wg US EPA:

[1] US Environmental Protection Agency. National primary drinking water regulations: disinfectants and disinfection by-products. Fed Regist 1998;63(241):69389.

Table 1
Stage 1 TOC removal requirements of the D/DBP Rule [1]

TOC concentration (mg/L)	Alkalinity, mg/L as CaCO ₃		
	0-60	60-120	>120
<2,0	No action	No action	No action
2,0-4,0	35%	25%	15%
>4,0-8,0	45%	35%	25%
>8,0	50%	40%	30%